



**District Department of the Environment
Underground Storage Tank Program**



**Public Records Data
Fiscal Year 2012**

Summary Information of Underground Storage Tank (UST) Systems

General Information

Public Record Post Date: October 31, 2012
 Total Number of Active UST Facilities: 256 (excludes heating oil facilities)
 Total Number of Active Tanks: 637 (excludes heating oil USTs)

Onsite Inspections-Significant Operational Compliance (SOC)

Inspection Period: October 1, 2011- September 30, 2012
 Number of UST Facilities Inspected
 (By DDOE only, does not include EPA/third party inspections in DC): 52
 Percent Compliance (combined measure): 88.46 % (46 of 52 facilities inspected)

SOC inspection information is based on reports from DDOE'S UST Inspectors, USEPA inspectors and certified Third Party inspectors under contract with the USEPA Region 3. Onsite inspections, measure compliance with DC Underground Storage Tank Management Regulations (20DCMR55-70) and Subtitle I of the Federal Resource Conservation and Recovery Act.

Summary Information for Releases

Release Reporting Period: October 1, 2011- September 30, 2012
 Number of Confirmed Releases: 22 (excludes heating oil releases)

Summary of Information for Release Sources and Causes

SOURCE			CAUSE													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
Individual Sources	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	4	18							2	50					2	
Piping																
Dispenser																
STP																
Delivery																
Other																
Unknown	18	82													18	100
TOTAL (All Sources)	22	100							2	9					20	91

To obtain further information, please contact the District Department of the Environment, Underground Storage Tank Program: Tel: (202) 299-3322, Fax: 202-535-1383 or E-mail: ust.ddoe@dc.gov.